

SSO Notification List												
October 2009												
Serial No.	Date of Occurrence	Location	Zip Code	Reason	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	10/2/2009	402 Key Highway	21230	Rags & Grease	Inner Harbor	2:00	4:00 PM - 6:00 PM	Sanitary Water	600	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	101380
2	10/4/2009	2501 W. Franklin Street	21223	Rags, Trash & Grease	Patapsco	0:40	9:50 AM - 10:30 AM	Sanitary Water	80	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	101413
3	10/17/2009	3700 Greenspring Ave	21211	Rags & Heavy Rain	Jones Falls	0:39	1:36 PM - 2:15 PM	Gray Water	78	Relieved M/L Choke with Pressure Truck	Regular Maintenance - Scheduled Cleaning	101781
4	10/18/2009	1800 Etting Street	21217	Rags & Grease	Jones Falls	5:45	9:15 AM - 3:00 PM	Gray Water	1,725	Relieved M/L Choke with Pressure Truck	Regular Maintenance - Scheduled Cleaning	101798
5	10/23/2009	6514 Pioneer Drive	21214	Rags, Roots & Grease	Herring Run	2:39	3:21 PM - 6:00 PM	Heavy Gray Water	795	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	102026
6	10/25/2009	3900 Harford Road	21218	Rags, Roots & Grease	Herring Run	3:00	11:00 AM - 2:00 PM	Heavy Gray Water	900	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	102057
7	10/28/2009	2900 Wynham Road	21216	Rags & Grease	Gwynns Falls	2:00	1:25 PM - 3:25 PM	Heavy Gray Water	600	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	102172
8	10/28/2009	10 N. Bethel Street	21231	Infilt/Inflow (Overcharged Line)	Inner Harbor	5:00	6:00 AM - 11:00 AM	Gray Colored Water	7,500	Jetted Line with Pressure Truck	Turned over to be CCTV'ed	102147
9	10/28/2009	401 E. Eager Street	21202	Infilt/Inflow (Overcharged Line)	Jones Falls	3:50	7:00 AM - 10:30 AM	Gray Colored Water	1,050	Jetted Line with Pressure Truck	Turned over to be CCTV'ed	102146
10	10/29/2009	3220 Sun Street	21226	Rags	Inner Harbor	5:24	12:34 PM - 5:58 PM	Sewer Water, Rags and Debris	324	Relieved M/L Choke with Cleaning Machine	Turned over to be CCTV'ed	102202
11	10/30/2009	2409 Everton Road	21209	Debris	Jones Falls	2:52	3:38 PM - 6:30 PM	Sewer Water	344	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	102245
								TOTAL	13,996			